

**Uttar Pradesh Pollution Control Board**

**T.C.-12V, Vibhuti Khand, Gomti Nagar, Lucknow**

No. Textile/102/18 - Inlet CETP

Date : 23-3-2018

**Draft Notification**

It is HEREBY notified for general information and for information of all persons affected thereby that in compliance of notification no.-S.O. 4(E) dated 01-01-2016 of Ministry of Environment, Forest and Climate Change, Government of India regarding standards for Common Effluent Treatment Plant (CETP), the Uttar Pradesh Pollution Control Board has in exercise of the power under clause (M) of sub-section (1) of section 17 of the Water(Prevention and Control of Pollution) Act, 1974, (Act No. 6 of 1974), laid down the draft inlet quality standards for Textile CETP as below:

Inlet Effluent Quality Standards for CETP					
	Apprale Park, Tronica City, Phase-1 & 2, Ghaziabad	Bhadohi Industrial Development Authority, Bhadohi, Varanasi	UPSIDC Textile Complex, Rooma, Kanpur	Industrial Area, Site-A, Mathura	CETP, Pilkhua, Ghaziabad
1	2	3	4	5	6
<b>General Parameters</b>					
pH	4.5-9.0	5.5-11.5	6.0-9.0	5-9	5.5-9.0
Colour, P.C.U (Platinum Cobalts Units)	350-400	350-400	350-400	350-400	350-400
Temperature °C	20-35	20-35	20-35	20-35	20-35
Oil & Grease	25	30	30	80-100	25
Total Suspended Solids	300	300	500-600	100-250	350
Biological Oxygen Demand (B.O.D.)	600	350	400-500	250-350	900
Chemical Oxygen Demand (C.O.D)	1200	700	1200-1400	1500-2000	1850
Fixed Dissolved Solids	As per notification no. SO4(E) dated 01-01-2016 of MoEF & CC.	As per notification no. SO4(E) dated 01-01-2016 of MoEF & CC.	As per notification no. SO4(E) dated 01-01-2016 of MoEF & CC.	As per notification no. SO4(E) dated 01-01-2016 of MoEF & CC.	As per notification no. SO4(E) dated 01-01-2016 of MoEF & CC.
Ammonical Nitrogen (As N)	50	50	50	50	50
Sodium Absorption Ratio (SAR)	26	26	26	26	26
<b>Specific Parameters</b>					
Total Chromium (as Cr)	2	2	2	2	2
Sulphide (as S)	2	2	2	2	2
Phenolic Compounds (as C <sub>6</sub> H <sub>5</sub> OH)	5	5	5	5	5


All values are mg/l. except pH, Colour and SAR.

Note-1- The above prescribed standards shall come into force on the date of their notification.

2- These standards are applicable irrespective of the mode of disposal.

It shall be the collective responsibility of all the member units of Common Effluent Treatment Plant to achieve the prescribed inlet standards.

All stack holders including Public/Private organizations and concerned citizens are requested to send the comments/suggestions/views on the draft inlet quality standards within 01 month of time i.e. by ~~22-4-2018~~. The comments should be sent through e-mail on [ms@uppcb.com](mailto:ms@uppcb.com), [info@uppcb.com](mailto:info@uppcb.com) and [ceo7@uppcb.com](mailto:ceo7@uppcb.com) and also through post at the official address mentioned above. The comments received beyond the deadline will not be considered.

  
Member Secretary